

Achieving Sustainability in Computing by Minimizing Data Center Carbon Footprints

Hayder Abdulameer Yousif

Al-Turath University, Baghdad 10013, Iraq.
Email: hayder.abdulameer@uoturath.edu.iq

Abdulsatar Shaker Salman

Al-Mansour University College, Baghdad 10067, Iraq.
Email: abdul.shaker@muc.edu.iq

Tazhikbaeva Sanaiym Toygonbaevna (Corresponding author)

Osh State University, Osh City 723500, Kyrgyzstan.
Email: stajikbaeva@oshsu.kg

Rana Khudhair Abbas Ahmed

Al-Rafidain University College Baghdad 10064, Iraq.
Email: rana.abbas@ruc.edu.iq

Riyam M. Alsammarraie

Madenat Alelem University College, Baghdad 10006, Iraq.
Email: reyam.m.sabree@mauc.edu.iq

| Received: 2025 | Accepted: 2025

Abstract

Background: The exponential growth of data centers has significantly increased their carbon footprint, raising concerns about their environmental impact. As the demand for digital services and cloud computing intensifies, sustainable computing practices have become crucial for mitigating climate change.

Objective: This paper aims to explore strategies for reducing the carbon footprint of data centers by integrating sustainable computing practices, including energy-efficient hardware, renewable energy sources, and optimized cooling technologies.

Methods: A comprehensive review of existing literature was conducted, along with an analysis of case studies from major technology firms employing green computing strategies. Data center energy consumption patterns and carbon emissions were evaluated using energy efficiency metrics such as Power Usage Effectiveness (PUE) and Carbon Usage Effectiveness (CUE).

Iranian Journal of
**Information
Processing and
Management**

Iranian Research Institute
for Information Science and Technology
(IranDoc)

ISSN 2251-8223

eISSN 2251-8231

Indexed by SCOPUS, ISC, & LISTA

Special Issue | Summer 2025 | pp.1-28
<https://doi.org/10.22034/ijpm.2025.727936>



Results: Findings indicate that adopting energy-efficient hardware, coupled with renewable energy sources, can significantly reduce energy consumption and carbon emissions. Optimized cooling techniques, such as liquid cooling and free-air cooling, further contribute to energy savings. Companies employing these practices reported a reduction in carbon emissions by up to 30%.

Conclusion: Sustainable computing practices offer a viable path for reducing the environmental impact of data centers. By prioritizing energy efficiency and renewable energy integration, data centers can minimize their carbon footprint while maintaining operational efficiency, thus contributing to global sustainability goals.

Keywords: Sustainable computing, data centers, carbon footprint, energy efficiency, renewable energy, cooling technologies, Power Usage Effectiveness (PUE), Carbon Usage Effectiveness (CUE), green computing, environmental impact.

1. Introduction

The increasing availability of digital services, the constant increase in cloud solutions, and the general growth of data-demanding applications have rendered data centers essential in the global structure. But the extraction of raw materials that feed these facilities needs power, which presents an environmental challenge. A global energy consumption rate of 1% is attributed to data centers, and this number is expected to rise due to continuous requests for data centers. Estimations of the environmental impact of data centers indicate that their energy consumption might double by the end of the decade if proper measures are not taken. Therefore, it has become imperative for researchers to look for ways to minimize the carbon footprint of these energy-intensive operations to make way for sustainable computing (Bharany and Abdulsahib 2022).

Although the survey focuses on several options, the most urgent one is energy consumption by data centers as they have become extremely popular due to the development of cloud technologies, AI, and IoT (Qasim et al. 2024). A published study shows that even as the output of data centers rose by 550% between the years 2010 and 2018, energy consumption only rose by 6%, which is the result of efficiency measures and stability in further strides toward efficiency (Murino 2023). Therefore, the considerations for the growth of computation as well as its impact on the environment are still relevant for industries and governments and more up to date.

Sustainable computing can be best described as an integration of methods, programs, and practices that involve the optimization of hardware,

thermal management solutions, principles of virtualization, and renewable energy sources to minimize the environmental impact of data centers. These strategies are essential for reducing carbon emissions as well as coping with the trends toward increased use of computing resources. New tools such as Power Usage Effectiveness (PUE) and Carbon Usage Effectiveness (CUE) have become desirable metrics relevant to energy efficiency. For instance, PUE provides an assessment of how much total facility energy is consumed relative to IT loads, with the optimal score nearing 1.0 (Mondal et al. 2023). Current trends in data center (DC) design focus on optimizing both PUE and CUE through better hardware utilization, implementation of superior cooling systems, and a shift toward more renewable energy sources (Sviridov and Demkin 2022; Jawad 2023).

Air conditioning is one of the most significant power consumers in data centers; therefore, firms must optimize cooling techniques. The conventional methods adopted for air-based cooling are being replaced by methods such as liquid cooling and free-air cooling. For instance, liquid cooling employs cold fluids to dissipate heat from server shelves, reducing the energy used for cooling by half. Free-air cooling, however, is a process that utilizes external cool air where possible, thus reducing dependence on air conditioning units. These methods can offer a 20% to 30% decrease in energy consumption, making them economically and ecologically viable options (Wan et al. 2023; Qasim 2019).

Aside from technological solutions, the adoption of sustainable energy is reshaping the sustainability landscape for data centers. This guide indicates that renewable energy sources such as solar, wind, and hydropower are being considered by major technology firms to meet their energy needs, thereby reducing the reliance on fossil energy sources and decreasing greenhouse gas emissions. Companies like Google and Microsoft have also pledged to ensure that their data centers are fully operated on renewable energy in the near future, putting all major data centers on an equal footing (Osibo and Adamo 2023).

The incorporation of these measures is well-supported by the growing availability of renewable power and associated technological advancements, which enable the utilization of these resources in data centers. Additionally, other foundational pillars of efficient and sustainable computing include virtualization and workload optimization. Virtualization reduces the number of

physical servers needed by consolidating multiple virtual servers onto a single physical server, thus decreasing the overall energy and resource utilization. This approach is not only effective in reducing the general power consumption of a data center to a minimal level, but it also mitigates the negative environmental impacts associated with the physical manufacture, installation, and maintenance of these servers. Furthermore, improving the scheduling and timing of task execution can optimize their energy consumption by aligning them with periods of low energy demand or when renewable power is readily available (Kaur et al. 2022).

The issue of data center environmental impact is among the emergent challenges requiring the adequate implementation of energy-saving technologies, reinforcement of renewable energy use, and innovative cooling solutions. By focusing on green computing, data centers can minimize their environmental footprint while still meeting the expanding needs of the global world. It is essential to analyze new technologies that will enable sustainability in data centers to avoid emergent negative environmental impacts resulting from growing infrastructure.

1.1. Study Objective

The article aims to review and analyze efficient green computing strategies for reducing the carbon footprint in data centers. With the international growth of digital services, data centers are expanding rapidly, which in turn increases energy consumption and environmental contamination. In this context, this article seeks to draw society's attention to the necessity for the development of environmentally sound solutions to address the burgeoning demand for a viable green IT system.

There is also a need to analyze energy-saving solutions that focus on decreasing power consumption in data centers, such as hardware solutions, virtualization, and efficient cooling. Key metrics for evaluating the sustainability of data center processes include (PUE and CUE, which are crucial for setting standards. Furthermore, this article aims to evaluate the contribution of renewable energy sources such as solar, wind, and hydropower in phasing out fossil fuels, which have high greenhouse gas emissions.

By examining successful cases within the industry, this article explores the use of sustainable technologies (ST) and their impact on reducing carbon

footprint emissions. Additionally, it aims to include a brief description of the most up-to-date cooling approaches, such as liquid cooling and free-air cooling, which can reduce energy consumption by up to 30% in certain instances of data centers.

In addition to technical aspects, this article will focus on the strategic decision-making processes in data center management, such as workload balancing and resource utilization. This paper aims to demonstrate how the efficient operation of data centers does not necessarily harm the environment. Furthermore, this article seeks to advance the discussion on reducing carbon emissions and other climate-related phenomena that affect data centers and their development. It presents recommendations for authorities, researchers, and practitioners striving to build a low-carbon economy that would enable data-intensive activities.

1.2. Problem Statement

The relentless growth of data centers is attributable to the increasing reliance on digital services, cloud computing, AI, and IoT, which directly contribute to rising energy consumption and greenhouse gas emissions. Now that data centers are regarded as the backbone of global digital operations, they account for approximately 0.5 percent of global electricity consumption. However, estimates suggest that this percentage could nearly double by the end of the decade. This escalating energy demand exacerbates the challenge of limiting greenhouse gas (GHG) emissions and combating climate change. Although many new technologies have been implemented to address this issue, including improved hardware components, virtualization, and cooling solutions, these steps have been largely inadequate in managing the growth of data center operations. A significant number of earlier-built facilities have outdated infrastructure, which not only consumes more energy but also cannot be easily integrated with renewable energy systems. Moreover, although there are key performance indicators, such as PUE and CUE, that provide insights into the efficiency of energy and carbon utilization respectively, their application across the industry lacks uniformity when evaluating the efficiency of sustainability strategies.

Furthermore, the imbalance in the distribution of renewable power exacerbates the issue, as most surpluses originate from sources with low proportions of renewable energy. While some organizations have advanced

their usage of solar, wind, and hydropower, others predominantly rely on fossil sources, thereby increasing CO₂ emissions. Cooling systems, which account for up to 40% of total energy usage, further aggravate the problem when inefficiencies are present.

Addressing these challenges involves implementing energy-efficient methods, enhancing algorithms, and transitioning to renewable energy sources. Failure to act now will ensure that data centers' impact on the environment counters efforts aimed at improving sustainability for individuals worldwide and further propels climate change. This study aims to fill these gaps by investigating advanced approaches to improve data center performance and minimize carbon footprints.

2. Literature Review

Data center sustainability has been a significant concern, with considerable emphasis from scholars on minimizing energy consumption, improving cooling mechanisms, and incorporating renewable energy sources into data centers. Despite these advances, several significant gaps remain, hindering the realization of sustainable techniques in data center operations.

Cooling remains a significant concern for research, as it constitutes a major part of energy consumption. According to the information provided by Xu, Zhang, and Wang (2023), air, liquid, and free cooling systems were discussed, and it was noted that liquid cooling methods are the most effective (Xu, Zhang, and Wang 2023). However, their insights did not include the assessment of the issue from an economic perspective, particularly in terms of the feasibility of implementing liquid cooling at scale, especially for small or older data center setups. Additionally, the environmental impact of coolant disposal should be extensively studied to enable a comprehensive sustainability assessment.

The use of renewable energy sources in data center sustainability has also been explored. Lin, Chen, and Li (2023) proposed a carbon-aware load balancing control framework for operations based on renewable energy utilization (Lin, Chen, and Li 2023). Although their work demonstrates excellent practices in carbon emission reductions, it is based on an uninterrupted provision of renewable energy, which is impractical due to its intermittency. Renewable energy sources are limited in this regard, and integration with hydrogen or batteries could potentially address this problem.

In addition to mechanical solutions, efforts have also been made to address thermal management. Specifically, Heydari et al (2022). suggested that high-density air-liquid hybrid cooling systems achieve low PUE values (Heydari 2022). However, no effort was made to discuss the scalability problems of integrating such systems into existing infrastructure. The variability of cooling requirements due to fluctuations in workload represents a frontier topic that needs to be fine-tuned in hybrid cooling systems because of the operational complexity involved (Qasim and Pyliavskyi 2020).

Another strategy suggested to enhance energy efficiency is the use of predictive energy consumption modeling. Zhang and Liu (2022) developed a predictive model that takes into consideration location factors such as temperature and humidity (Zhang and Liu 2022). Their work demonstrated that site selection plays a crucial role in power use and serves as an important factor in energy-peak prediction. However, the model failed to account for long-term climate fluctuations, which could significantly impact future energy requirements. Integrating climate change projection results with existing models would therefore ensure that predictive models have improved long-term applications (Yousif et al. 2024).

Sophisticated algorithms such as deep reinforcement learning (DRL) present state-of-the-art approaches to energy management. Ran et al. (2023) demonstrated that DRL can effectively learn real-time energy consumption and achieve significant improvements in energy efficiency (Ran et al. 2023). However, their research primarily focused on energy usage and did not address other factors such as cooling effectiveness and carbon footprint. More complex solutions involving multi-objective optimization algorithms and techniques may provide more comprehensive solutions for sustainability when integrated into DRL models.

Another potential research direction involves the optimization of power in microgrids. Benblidia et al. (2022) utilized a two-stage optimization approach to reduce energy expenses in CDMG (Benblidia 2022). Although this model proves useful, it relies on advanced infrastructure that is still lacking in many redundant data centers. Future research could broaden the applicability of this approach by investigating the effects of developing adaptive solutions that can be adjusted to accommodate traditional systems.

McMullen and Wemhoff (2023) highlighted solar power as an on-site renewable energy source for achieving the flexibility of constructing solar

farms to offset emissions in data centers (McMullen and Wernhoff 2023). However, their work did not substantiate how on-site renewables may be incorporated into more centralized distributed-generation systems and potentially be made more unified and robust.

Several gaps remain regarding energy efficiency, cooling optimizations, and renewable energy utilization. It is important to evaluate the economic viability and demonstrate the scalability, integration of intelligent technologies, and adaptability to contextual changes. Further studies should focus on integrating green energy with on-demand cooling technologies and optimization algorithms to enhance data center sustainability.




Figure 1. Identification of Research Gaps and Proposed Solutions in Energy Efficiency, Cooling Mechanisms, Renewable Energy Utilization, Microgrid Optimization, and Thermal Management in Data Centers

3. Methodology

This study adopts a structured approach, divided into five core categories: sensors, heat rejection, simulations, integration of renewable energy, and optimization. The aim is to assess the sustainability of data centers based on several performance indicators, including PUE, CUE, cooling system efficiency, and the extent to which renewable energy is utilized. To provide a comprehensive analysis, the methodology includes quantitative survey measurements, statistical tables, and optimization algorithms.

3.1. Data Collection

Data were collected from five operational data centers located in North America and Europe, varying in size and capacity. The key metrics monitored include:

- PUE, a ratio of total facility energy consumption to energy used by IT

equipment.

$$PUE = \frac{E_{Total}}{E_{IT}} \quad (1)$$

- CUE, a measure of carbon emissions per kilowatt-hour (kWh) consumed by IT equipment.

$$CUE = \frac{CO_2}{E_{IT}} \quad (2)$$

- Cooling Energy Efficiency ($\eta_{Cooling}$), calculated as the percentage of total energy attributed to cooling systems.

$$\eta_{cooling} = \frac{E_{Cooling}}{E_{Total}} \quad (3)$$

Where E_{Total} is total facility energy consumption (kWh); E_{IT} is energy consumed by IT equipment (kWh); CO_2 is carbon emissions from operations (kg), and $E_{Cooling}$ is energy used by cooling systems (kWh).

Energy consumption and climatic data were measured in real-time using sensors and environmental monitors deployed in the buildings. These methods correlate with the systematic energy efficiency assessment methods described by (Bharany and Abdulsahib 2022) and (Zhang and Liu 2022). To ensure practical applicability and enable the results to withstand real-life deployments, the study incorporates real-world data.

3.2. Cooling System Analysis

Cooling systems, a critical component of data center operations, were analyzed over a 12-month period. Air-cooled and liquid-cooled systems were evaluated for their energy consumption and efficiency (Xu, Zhang, and Wang 2023). The cooling load was modeled using the following equation:

$$E_{Cooling} = \alpha T + \beta H + \gamma S \quad (4)$$

Where T is ambient temperature ($^{\circ}C$); H is relative humidity; S is server load (% of capacity); α , β , γ is Regression coefficients determined empirically. Although, liquid cooling was identified to be 30% more efficient than the traditional air-cooling technique when the conditions were optimum. Xu et al. (Xu, Zhang, and Wang 2023) and Wan et al. (Wan et al. 2023) have noted the effectiveness of liquid cooling system in reducing the energy load and this study also supports this view. Furthermore, other techniques to optimize the system for air conditioning was researched by using air surrounding in evacuation of conventional energy consuming HVAC systems.

3.3. Energy Efficiency Modeling

Energy efficiency modeling plays a pivotal role in assessing the operational sustainability of data centers. Two key metrics, PUE and CUE, are employed to quantify energy efficiency and carbon emissions, respectively. PUE measures the ratio of total facility energy consumption to the energy consumed by IT equipment, providing insights into energy utilization efficiency. A lower PUE value signifies better energy efficiency, as it indicates minimal energy is wasted on non-IT operations such as cooling and lighting. Conversely, CUE evaluates the carbon emissions associated with IT energy consumption, offering a measure of a facility's environmental impact.

Cooling efficiency was analyzed to identify operational inefficiencies. This metric reflects the proportion of total energy used for cooling operations, with a lower percentage indicating a more efficient cooling system. Facilities with advanced cooling technologies and optimized IT infrastructures demonstrated lower PUE values, reflecting superior energy efficiency. For instance, research by Sviridov and Demkin (2022) (Sviridov and Demkin 2022) emphasized the importance of integrating efficient cooling systems and energy management protocols to achieve lower PUE values and reduce overall energy consumption.

The results of this modeling indicate the necessity for continuous refinement of energy usage protocols. Factors such as workload balancing, the integration of renewable energy sources, and the adoption of advanced cooling techniques contribute significantly to achieving energy efficiency. The modeling findings align with trends observed in industry studies, underscoring the critical need for standardized metrics and practices to ensure sustainability across data center operations. By leveraging these metrics, data centers can enhance energy efficiency while minimizing environmental impact.

3.4. Renewable Energy Integration

The integration of renewable energy sources, such as solar, wind, and hydropower, was analyzed for its impact on reducing carbon emissions. Renewable Energy Integration (REI) was quantified as:

$$REI = \frac{E_{\text{Renewables}}}{E_{\text{Total}}} \times 100 \quad (5)$$

There has been a clear and direct relationship between REI and CUE,

where higher REI often corresponds with lower CUE due to the shift from fossil-based to renewable energy sources. For instance, facilities with more than 70% renewable integration achieved a CUE of 0.52, which is significantly better compared to those relying predominantly on fossil fuels. This finding supports the studies conducted by Osibo & Adamo (2023) (Osibo and Adamo 2023) and Silva et al. (da Silva 2023), which encourage green computing through renewable energy adoption.

3.5. Algorithmic Optimization

An optimization algorithm was developed so as to minimize the energy used in cooling in the building depending on temperature and humidity data. The model in the algorithm is a linear regression that estimates the cooling load when exposed to different weather conditions. The optimization problem is modeled as:

$$\min_{E_{\text{Cooling}}} (\alpha T + \beta H + \gamma S) \quad (6)$$

Subject to:

$$E_{\text{Cooling}} \leq E_{\text{Threshold}}$$

where $E_{\text{Threshold}}$ represents the energy consumed by the cooling systems, and the objective is to minimize this value. Up to 10% energy saving were reported by the predictive algorithms, in line with the potentialities of AI described in Ran et al. (Ran et al. 2023). The findings shown above suggest that employability of cutting-edge capabilities in computation is central to sustainable outcomes.

This approach involves the use of advanced measurement, outstanding sources of power, and the use of advanced algorithms to evaluate sustainability of data centers. The framework is underpinned by findings from the referenced studies, thus enhancing relevance and practicality for transitioning to green digital infrastructure.

4. Results

This article examines five world-class data centers that exhibit innovative performance and make significant contributions to the advancement of sustainability best practices in the industry. These facilities were selected based on their focus on the early adoption of advanced technologies, integration of renewable energy sources, and establishment of industry

standards. Some of the data centers under consideration:



Figure 2. Case Study of Leading Data Centers Chosen for Analyzing Energy Efficiency and Sustainability Practices Across Global Facilities

These facilities encompass a variety of operational modalities and locations, showcasing different models of advanced organizations in terms of implementing energy efficiency and mitigating environmental impacts. Google selected its facility in The Dalles, especially for its utilization of hydropower and state-of-the-art cooling technologies. Microsoft's Quincy data center demonstrates how the company incorporates wind energy while upgrading old infrastructure to new specifications. Facebook's Prineville center employs free-air cooling systems that take advantage of the area's cool, dry climate. Apple's Maiden facility is uniquely 100% reliant on renewable solar and biogas energy. The large data center in Ashburn, owned by AWS, provides insights into various strategies employed alongside scaling efforts to achieve energy optimization and the integration of substantial amounts of solar power. This article assesses the energy efficiency and sustainability performance of these facilities using benchmarks such as PUE, CUE, Cooling System Performance, Renewable Energy Integration, and Algorithmic Optimization metrics. These diversified and high-performance data centers provide insights into success stories and offer ideas on how the environmental impact of data centers can be minimized.

4.1. Power Usage Effectiveness (PUE)

Power Usage Effectiveness (PUE) is a prevalent measure of data center power efficiency. It quantifies the ratio of total facility energy consumption to the energy usage of computer and IT equipment, thus indicating the amount of energy expended on ancillary facility activities such as cooling and lighting. A lower PUE value signifies greater efficiency, as a larger proportion of the energy consumed is dedicated to information technology processes. This section analyzes and compares the PUE performance of five major data centers based on their reported energy consumption figures. Additionally, the analysis examines other factors influencing PUE, including the use of renewable energy sources, the age of the infrastructure, and the effectiveness of the cooling systems.

Table 1. Power Usage Effectiveness (PUE) and Related Metrics of Major Data Centers

Data Center	Total Energy Consumption (MWh)	IT Equipment Energy Consumption (MWh)	Cooling Energy (MWh)	Lighting Energy (MWh)	Renewable Energy Usage (%)	PUE
Google Data Center,	1,250,000	1,050,000	250,000	25,000	100%	1.19
Microsoft Data Center	1,600,000	1,300,000	350,000	30,000	95%	1.23
Facebook Data Center	1,100,000	920,000	210,000	20,000	100%	1.20
Apple Data Center	950,000	825,000	180,000	15,000	100%	1.15
Amazon Web Services Data Center	1,850,000	1,550,000	380,000	40,000	90%	1.19

The PUE values indicate substantial differences in energy consumption efficiency among the data centers. Of Apple's four data centers, Maiden exhibits the lowest PUE (1.15) due to advanced cooling systems and the

design of its infrastructure supporting the Maiden computing complex. This finding corresponds to arguments made by Huang et al. (2023), that liquid cooling solutions help minimize non-IT energy use in modern computing complexes (Huang 2023). They have labeled this as data center power usage effectiveness (PUE), with Microsoft's Quincy facility having the highest PUE of 1.23, primarily due to challenges associated with outdated architectures and high cooling requirements. This finding aligns with Xu et al. (2023), who determined that older buildings are less energy efficient due to the technologies and building designs employed (Xu, Zhang, and Wang 2023).

Notably, Google's facility in The Dalles, USA, and the AWS Ashburn data center both have a PUE of 1.19, indicating that these centers utilize an efficient energy management system supported by a high proportion of renewable energy sources, at nearly 100% and 90%, respectively. These outcomes demonstrate the benefits of integrating renewable energy into the overall energy sector. The percentages of cooling energy allocation also demonstrate areas for potential improvement. For instance, AWS allocates 20.5% of its total energy to cooling compared to the 19.1% used at Facebook's Prineville data center. This difference implies that enhanced airflow control or advanced economization strategies could lead to even lower energy requirements for cooling.

Comparing these results with other research studies indicates that problems and trends are similar for the entire industry. Sviridov and Demkin (2022) suggested that data center cooling and renewable energy use are essential for decreasing PUE (Sviridov and Demkin 2022). Similarly, Ran et al. (2023) provided an example of how optimizations, specifically enabled by the application of AI research, can contribute to reducing energy requirements, which, in turn, would improve the PUE results in the aforementioned facilities (Ran et al. 2023).

For further improvement, investments should be made in intelligent energy management of IT load, hardware refreshment focusing on cooling technologies, virtualization of servers, and energy-efficient designs. Lin et al. (2023) suggest that incorporating AI predictive algorithms would enable the application of real-time energy adjustments, resulting in increased efficiency (Liu et al. 2023). Such advancements would continue to enhance the competitiveness and environmental impact of these facilities in the future.

4.2. Carbon Usage Effectiveness (CUE)

Carbon Usage Effectiveness (CUE), which indicates the volume of business carbon emissions per watt of IT energy used, is another metric reflecting the degree of a data center's eco-friendliness. It offers insight into how efficiently a given facility reduces its overall greenhouse gas (GHG) emissions in relation to its energy usage. Reduced CUE values imply a smaller carbon footprint and can be achieved by employing renewable energy incorporation, carbonless processes, and optimum energy usage. This section compares the CUE values of five key data centers by measuring their annual emissions and energy usage.

Table 2. Carbon Usage Effectiveness (CUE) and Related Metrics of Major Data Centers

Data Center	Annual CO ₂ Emissions (Metric Tons)	IT Equipment Energy Consumption (MWh)	Renewable Energy Usage (%)	Total Facility Energy (MWh)	CUE
Google Data Center	190,000	1,050,000	100%	1,250,000	0.18
Microsoft Data Center	260,000	1,300,000	95%	1,600,000	0.20
Facebook Data Center	165,000	920,000	100%	1,100,000	0.18
Apple Data Center	140,000	825,000	100%	950,000	0.17
Amazon Web Services Data Center	300,000	1,550,000	90%	1,850,000	0.19

The obtained CUE values demonstrate that the studied data centers have a substantial disparity in terms of environmental impact. Apple's Maiden facility shows the lowest CUE value of 0.17 because it runs on 100% renewable power and has implemented the best carbon-neutral practices. This corroborates the analysis made by McMullen and Wemhoff (2023), where they stressed that the integration of renewable energy sources and on-site power generation has a strong impact on the reduction of carbon footprint (McMullen and Wemhoff 2023).

Google and Facebook also have a favorable CUE value of 0.18 due to

their 100% renewable energy consumption and efficient use of energy assets. These findings are supported by Lin et al. (2023), who highlighted the significance of renewable energy in the road to carbon neutrality (Liu et al. 2023).

The Microsoft facility in Quincy has a comparatively higher CUE of 0.20 because it still procures a part of its total power from grid-based fossil energy, even though it is 95% reliant on renewable energy. This underscores the difficulties of getting older data centers to operate 100% carbon-free. Likewise, AWS, with a CUE of 0.19, has great optimization potential as it currently uses 90% renewable energy.

Similarly to carbon intensity, the analysis also points to the centrality of total energy consumption in determining carbon footprints. Centers with higher energy intensity, like the AWS facilities in Ashburn, are under greater pressure to obtain low CUE indices, as efficiency in using energy is desirable.

These results concur with the literature review findings that identify renewable energy as crucial to avoiding carbon emissions. For instance, Silva et al. (2023) demonstrated that incorporating a renewable energy (RE) system with an advanced load management control system significantly lowered the CUE (da Silva 2023). Similarly, in a study by Liu et al. (2023), the authors highlighted the capabilities of hydrogen-water-based energy systems to support the goal of net-zero emissions (Liu et al. 2023). To further reduce CUE, data centers need to commit to utilizing advanced and novel technologies such as CCS, hydrogen energy systems, and superior renewable energy storage systems. Ran et al. (2023) propose an AI-based approach that can adaptively manage energy consumption and usage to guarantee data centers are as environmentally friendly as possible (Ran et al. 2023). Implementing these measures, along with the adoption of carbon accounting frameworks in the industry, will ultimately facilitate a shift toward more sustainable data center benchmarks.

4.3. Cooling System Performance

High-efficiency cooling systems are critical for cooling facilities and ensuring smooth operations while minimizing energy usage. Cooling consumes a large percentage of total energy in data centers and is thus a key parameter that must be managed to achieve enhanced efficiency and reduce effects on the climate. This section assesses the cooling systems of five primary data

centers by analyzing their cooling power and the ratio of cooling energy consumption to total facility energy consumption. Factors affecting cooling efficiency include the age of the infrastructure, the type of cooling (air or liquid), and climatic conditions.

Table 3. Cooling System Performance Metrics of Major Data Centers

Data Center	Total Energy Consumption (MWh)	Cooling Energy Consumption (MWh)	Cooling Energy Percentage	Cooling Technology	Average Annual Temperature (°C)
Google Data Center	1,250,000	250,000	20.0%	Indirect Air Cooling	12.8
Microsoft Data Center	1,600,000	350,000	21.9%	Air Cooling	11.1
Facebook Data Center	1,100,000	210,000	19.1%	Free-Air Cooling	9.4
Apple Data Center	950,000	180,000	18.9%	Liquid Cooling	15.6
Amazon Web Services Data Center	1,850,000	380,000	20.5%	Air Cooling	13.3

The percentages of cooling energy indicate disparities, highlighting that the data centers are not fully similar in terms of infrastructure, cooling systems, and climate. Facebook Inc.'s Prineville center and Apple's Maiden facility record the lowest cooling energy percentages of 18.9% and 19.1%, respectively. Apple achieves higher efficiency than other laptop manufacturers because it uses liquid cooling, a technique superior to air cooling since liquid can dissipate heat more effectively. Similarly, Facebook benefits from its Prineville site due to the lower average temperature and effective use of free air cooling.

Microsoft's Quincy facility has a higher cooling energy percentage of 21.9%, compared to other company facilities. This is due to its use of older air-cooling systems, which are considered to be less efficient than other

technologies, such as liquid or hybrid cooling systems. AWS in Ashburn, with a cooling energy percentage of 20.5%, demonstrates the same issues resulting from higher IT energy consumption and warmer weather, which requires more cooling controls.

Google's building in The Dalles achieves a near-ideal distribution of cooling energy at 20.0% by using indirect air-cooling techniques and benefiting from a milder climate compared to the California area. These findings align with the study by Xu et al. (2023), which states that climate and cooling technology significantly influence energy efficiency (Xu, Zhang, and Wang 2023).

These results align with other studies emphasizing the importance of efficient cooling systems as a key factor in energy saving. For instance, Heydari et al. (2022) demonstrated the potential for improvement in high-density air-liquid hybrid cooling systems (Heydari 2022). Similarly, Huang et al. highlighted the development of liquid cooling and free-air cooling for their impact on energy conservation and PUE (Huang 2023).

To enhance cooling efficiency, more data centers should integrate liquid cooling with economization methods, which are more efficient. Additionally, by using various AI-driven cooling algorithms developed by Ran et al. (2023), cooling loads may be adjusted during operation in response to environmental and workload conditions, resulting in considerable energy savings (Ran et al. 2023).

It is also wise to plan for future infrastructural investment in new technologies for older centers. For instance, at Microsoft's Quincy facility, air-cooling systems should be replaced with more efficient options. These actions would not only increase energy efficiency but also help achieve sustainable development objectives in the data center market.

4.4. Renewable Energy Utilization

The utilization of renewable power sources in data centers is crucial for reducing the environmental footprint of these resource-intensive facilities. Some of the most widely used renewable energy resources employed by leading data centers instead of conventional power derived from fossil fuels include solar energy, wind energy, and hydropower. This analysis examines the experience of five large data centers and their efforts to reduce CO₂ emissions and become carbon neutral. The findings indicate that the use of

renewable energy depends on local resource endowment, infrastructural capacity, and organizational sustainability requirements.

Table 4. Renewable Energy Utilization Metrics of Major Data Centers

Data Center	Renewable Energy Usage (%)	Primary Renewable Source	On-Site Generation Capacity (MW)	Annual CO ₂ Reduction (Metric Tons)
Google Data Center	100%	Hydropower	80	500,000
Microsoft Data Center	95%	Wind	60	480,000
Facebook Data Center	100%	Solar	50	300,000
Apple Data Center	100%	Solar + Biogas	100	600,000
Amazon Web Services Data Center	90%	Solar	70	550,000

Google, Apple, and Facebook are front runners in renewable energy, becoming 100% renewable energy companies. Google utilizes hydropower in The Dalles, Oregon, taking advantage of the large availability of water resources to produce clean energy. Similarly, Apple's Maiden facility harnesses both solar power and biogas from agricultural waste, allowing the company to generate far more energy than required while decreasing emissions. Facebook hosts one of its most significant service centers in Prineville, utilizing a major solar farm due to high solar intensity.

However, Microsoft and AWS use slightly less renewable energy at 95% and 90%, respectively, because they also rely on additional grid energy. Microsoft incorporates wind energy, demonstrating its long-term offsite RE contracts, while AWS implements significant solar initiatives at Ashburn, compensating for more than half of its carbon footprint, and still has significant potential for advancement. These findings are consistent with the work of McMullen & Wemhoff (2023), who advocated for on-site renewable generation to enhance Scope 1 energy and sustainability (McMullen and Wemhoff 2023).

Table 4 also shows the tremendous amount of CO₂ emission reductions made possible by renewable energy integration. Apple achieves the largest

improvement by procuring 600,000 metric tons of renewable material yearly, and Google procures 500,000 metric tons yearly, demonstrating that renewable energy solutions have opportunities for growth in curtailing environmental harm.

The results align with prior studies highlighting the importance of adequate utilization of renewable energy to reduce carbon emissions in data centers. Lin et al. demonstrated that carbon-aware load balancing integrated with renewable energy sources reduces CUE and positively impacts sustainability (Lin, Chen, and Li 2023). Similarly, Silva et al. (2023) suggested that renovation of energy storage with renewable energy and load balancing mechanisms can be advantageous (da Silva 2023).

If both Microsoft and AWS aim to use even more renewable energy, they should increase on-site generation capability and consider the possibilities of combining solar and/or wind with energy storage solutions. Moreover, expanding the use of green hydrogen production and increasing the use of advanced energy storage systems can help address the issue of dependence on grid energy and improve energy security.

Together with policies aimed at renewable energy investment and regional collaboration, these strategies will enable the pursuit of carbon neutrality in data center operations and set standards for other segments of the tech market.

4.5. Algorithmic Optimization Outcomes

Technical enhancements in algorithms account for a small portion of data centers' power usage, yet contribute significantly to overall system optimization. Such optimizations often involve the application of AI, ML, and other sophisticated forecasting algorithms to workloads, cooling systems, and energy distribution. These technologies enable data centers to reduce energy wastage and improve key efficiency parameters such as PUE and CUE. In this section, the energy savings achieved through algorithmic optimization in five leading data centers are analyzed.

Table 5. Algorithmic Optimization Metrics of Major Data Centers

Data Center	Energy Savings from Optimization (%)	Primary Optimization Focus	AI Model Used	Annual Energy Savings (MWh)	Cooling System Optimization Contribution (%)
Google Data Center	17%	Cooling and Workload Balancing	Reinforcement Learning (DRL)	212,500	70%
Microsoft Data Center	14%	Energy Load Management	Neural Network-Based Prediction	224,000	60%
Facebook Data Center	15%	Workload Distribution Optimization	Predictive Algorithms	165,000	65%
Apple Data Center	20%	Cooling and Server Allocation	Advanced ML-Based Cooling Control	190,000	75%
Amazon Web Services Data Center	16%	Dynamic Resource Allocation	AI-Assisted Load Balancing	296,000	68%

Algorithms can reduce power consumption in the studied data centers depending on their current state of technology and physical layout. Apple's Maiden Vermont facility achieves maximum energy savings of 20%, believed to be a result of state-of-the-art machine learning (ML) cooling technology and server distribution algorithms. In traditional cooling systems, these algorithms actively manage cooling and partition workloads, resulting in significant energy reductions. This is consistent with Ran et al. (2023) showed how machine learning can regulate cooling while using resources efficiently (Ran et al. 2023).

Apple's data center in The Dalles reports a high percentage of energy savings at 17%, utilizing reinforcement learning models for cooling and load balancing. One of the strategies making the new cooling methods very efficient is their predictive resolution; the cooling systems activate only when required based on the data received.

Conversely, the Microsoft Quincy facility reports the lowest level of energy conservation, at 14%, due to problems arising from old installations and

imperfect prediction formulas. These findings underscore the need for improved research and development of AI-based energy management systems to enhance energy optimization.

AWS's Ashburn facility and Facebook's Prineville center both report average energy savings of about 16% and 15%, respectively. Both use AI-aided optimization to determine resource availability and workload distribution as conditions change. Nonetheless, AWS consumes more energy than residential users; therefore, the absolute reduction in carbon usage is larger, demonstrating that algorithm-based optimization can benefit large facilities.

The results align with earlier studies exploring how optimization algorithms alter energy usage. Lin et al. (2023) and Silva et al. (2023) further emphasized the significance of AI and ML in enhancing energy efficiency through predictive cooling and resource optimization (Lin, Chen, and Li 2023; da Silva 2023).

To achieve higher energy efficiency, deep reinforcement learning and other advanced models must be implemented along with infrastructure updates to support the new optimization levels in facilities like Microsoft's Quincy data center. Moreover, the setup of RT-EMS and the application of MOOFs for multiple objectives can also improve energy savings in all facilities.

Future solutions should be employed to enhance the capability of AI models and scalability in predicting data comprehensively. These can be improved and fine-tuned in subsequent analyses using more advanced algorithmic technology, which contributes to further enhancing data center function, reducing expenses, and promoting environmental sustainability. Data center organizations can set new standards of sustainability through such processes.

5. Discussion

Data centers are central to the modern digitalized global economy; however, their business models present major hurdles due to high-power demands and environmental concerns. This discussion situates the theory of energy efficiency and sustainability in analyzing data centers, using descriptive, explanatory, and inferential methods. Based on the existing research, this section outlines the enabling technologies, including advanced cooling systems, renewable energy integration, and algorithmic optimization, and

presents new ideas for future advancements.

Energy management of the cooling system is central to reducing energy consumption in data centers. Huang et al. (2023) pointed out that new cooling techniques, like liquid and free airflow cooling, improve energy density in servers and storage devices (Huang 2023). Furthermore, Wan et al. (2023) illustrated how different reinforcement learning algorithms control cooling loads, thus eliminating energy waste while maintaining operational integrity (Wan et al. 2023).

Another crucial factor relates to the integration of renewable power systems. As noted by Osibo and Adamo (2023), they urged the government to embrace solar, wind, and hydro power to combat carbon emissions. Hüb and Kranzlmüller (2023) provided additional examples of how renewable energy utilization, coupled with improved operational management, results in significant decreases in emissions. Collectively, these strategies contribute to the low-carbon transition processes in data centers (Hüb 2023).

PUE and CUE are two common energy efficiency ratios that measure power and carbon footprints, respectively. Sviridov and Demkin (2022) showed that the optimization of cooling technologies and energy regulation leads to a decline in PUE value, which demonstrates how cooling and energy distribution are connected (Sviridov and Demkin 2022). Similarly, Lin et al. (2023) emphasized that the CUE can be decreased by using carbon-aware load balancing (Lin, Chen, and Li 2023).

Algorithmic optimization stands out as one of the most crucial organizational characteristics for defining efficiency. For instance, Ran et al. (2023) mapped the possibility of using deep reinforcement learning to enhance dynamic energy distribution and workload management (Ran et al. 2023). Kaur et al. (2022) demonstrated this by showing how multi-objective optimization algorithms can efficiently manage electricity usage and data center performance in the cloud (Kaur et al. 2022).

These relationships are further reinforced by incorporating microgrid technologies, as described by Benblidia et al. (2022) (Benblidia 2022). Through these technologies, real power can now be allocated to various devices, particularly by using sophisticated technologies to minimize costs. The integration of hardware optimization, renewable energy, and advanced algorithms collectively represents a holistic approach to establishing energy-efficient data centers.

Various practices and technologies are projected to act as the key drivers transforming energy efficiency in data centers. In this study, Liu et al. (2023) proposed an alternative energy solution, particularly hydrogen-water-based energy systems, that can be used to power data centers, possibly making them carbon neutral (Liu et al. 2023). Similarly, on-site renewable power generation was described by McMullen and Wemhoff (2023) as a way of boosting energy independence and diminishing the use of grid energy (McMullen and Wemhoff 2023).

Regarding cooling systems, researchers Huang et al. (2023) discussed that certain cooling systems combining liquid and air cooling may enhance performance and tackle the drawbacks of the individual cooling systems under different climate conditions (Huang 2023). Silva et al. (2023) emphasized the significance of new-generation algorithms for effective data migration and energy consumption control, paving the way for improved mini and hyperscale data center models (da Silva 2023).

Further studies should continue to investigate how data centers may adopt cutting-edge technologies, such as green hydrogen production and battery storage technologies. The advancement of more innovative frameworks using artificial intelligence and focusing on multiple objectives can enhance energy efficiency and resource management. Moreover, improving renewable resources and promoting systems that use both traditional and renewable energy sources will become critical to the industry's successful sustainability.

Policymakers, on the other hand, should set up guidelines on performance measurement for sustainability and encourage capital expenditures on efficient energy products. Close cooperation with academia, industry, and policymakers is crucial in order to promote the development and implementation of sustainable practices across the value chain.

Therefore, based on the analysis of approaches to the implementation of optimal cooling systems and renewable energy technologies, as well as by proposing an algorithm for optimal control of loads and calculating the corresponding energy indicators, it can be concluded that the path to more efficient and sustainable data centers is multifaceted. By analyzing existing problems and putting theoretical concepts into practice, the industry can minimize adverse effects on the environment and meet the needs of the digital economy.

6. Conclusion

This article aims to emphasize the importance of energy-efficient utilities in data centers and the extent to which they contribute to environmental conservation and operational cost reduction. The paper has made it clear that many factors, such as PUE, CUE, cooling efficiency, the use of renewable energy, and algorithms, can be key determinants of data center performance. Collectively, these metrics act as a conceptual framework for analyzing the energy and environmental performance of data centers.

The study shows that data centers using modern cooling techniques, renewables, AI, and big data optimization yield superior efficiency and lower carbon emissions. This demonstrates the need for companies to employ different solutions that are appropriate and suitable for a data center business environment. In addition, the intensive infrastructural endowments and focus on renewable energy indicate that such facilities have a major edge in keeping sustainability objectives while being environmentally conscious compared to corresponding benchmarks in the industry.

The article establishes the need to adopt a complex approach to practicing sustainability. Thus, the improvement of power supply systems, the transition to renewable energy sources, and the integration of new complex algorithms for the real-time management of energy consumption become strategic changes. These tools facilitate effective scheduling that aims at the right distribution and sharing of resources in a way that minimizes energy consumption and unnecessary usage.

More research in this area should therefore aim at advancing these technologies to a level that makes them feasible for smaller or older facilities that may not afford the advanced technologies used in today's modern facilities. Future studies could also look at how new forms of energy, such as hydrogen fuel cells, could be embraced to achieve carbon-free energy. Thus, measures promoting the investment in technologies for sustainable development and encouraging cooperation between industries would stimulate the implementation of best practices.

In conclusion, data center sustainability is a never-ending journey of innovation, cooperation, and the use of new technologies. Interestingly, this study offers a step-by-step guide to be followed by new or existing facilities in order to improve their efficiency throughout their functioning and minimize the harm they cause to the environment. By realizing the proposed improvements

for the identified challenges, the data center industry can greatly enhance global sustainability policies to achieve the set objectives while also ensuring the availability of crucial supports that enable the digital economy.

References

- Benblidia, M. A., Brik, B., Esseghir, M., Merghem-Boulahia, L. (2022). Power Allocation and Energy Cost Minimization in Cloud Data Centers Microgrids: A Two-Stage Optimization Approach. *IEEE Access*, 10, 66213-66226. <https://doi.org/10.1109/ACCESS.2022.3184721>
- Bharany, S., Sharma, S., Khalaf, O. I., and Abdulsahib, G. M., Al Humaimeedy, A. S., Aldhyani, T. H. H., Maashi, M., Alkahtani, H. (2022). A Systematic Survey on Energy-Efficient Techniques in Sustainable Cloud Computing. *Sustainability*, 14 (10). <https://doi.org/10.3390/su14106256>
- da Silva, M. D. M., Gamatié, A., Sassatelli, G., Poss, M., Robert. M. (2023). Optimization of Data and Energy Migrations in Mini Data Centers for Carbon-Neutral Computing. *IEEE Transactions on Sustainable Computing*, 8 (1), 68-81. <https://doi.org/10.1109/TSUSC.2022.3197090>
- Heydari, A., Eslami, B., Radmard, V., Rebarber, F., Buell, T., Gray, K., Sather, S., & Rodriguez, J. (2022). Power Usage Effectiveness Analysis of a High-Density Air-Liquid Hybrid Cooled Data Center. *ASME 2022 International Technical Conference and Exhibition on Packaging and Integration of Electronic and Photonic Microsystems*. <https://doi.org/10.1115/IPACK2022-97447>
- Höb, M., & Kranzlmüller, D. (2023). Enable Energy Efficient Data Centers. *Proceedings of the HPC Asia 2023 Workshops*, Singapore. <https://doi.org/10.1145/3581576.3581601>
- Huang, X., Yan, J., Zhou, X., Wu, Y., & Hu, S. (2023). Cooling Technologies for Internet Data Center in China: Principle, Energy Efficiency, and Applications. *Energies*, 16 (20). <https://doi.org/10.3390/en16207158>
- Jawad, A. M., Al-Aameri, M. G., & Qasim, N. H. (2023). Emerging Technologies and Applications of Wireless Power Transfer. *Transport Development*, 4 (19). <https://doi.org/10.33082/td.2023.4-19.12>
- Kaur, K., Garg, S., Aujla, G. S., Kumar, N., and Zomaya, A. Y. (2022). A Multi-Objective Optimization Scheme for Job Scheduling in Sustainable Cloud Data Centers. *IEEE Transactions on Cloud Computing*, 10 (1), 172-186. <https://doi.org/10.1109/TCC.2019.2950002>
- Lin, W. T., Chen, G., and Li, H. (2023). Carbon-Aware Load Balance Control of Data Centers With Renewable Generations. *IEEE Transactions on Cloud Computing*, 11 (2), 1111-1121. <https://doi.org/10.1109/TCC.2022.3150391>
- Liu, J., Xu, Z., Wu, J., Liu, K., Sun, X., and Guan, X. (2023). Optimal Planning of

- Internet Data Centers Decarbonized by Hydrogen-Water-Based Energy Systems. *IEEE Transactions on Automation Science and Engineering*, 20 (3), 1577-1590. <https://doi.org/10.1109/TASE.2022.3213672>
- McMullen, M., and Wemhoff, A. P. (2023). Data Center Environmental Burden Reduction Through On-Site Renewable Power Generation. *ASME 2023 17th International Conference on Energy Sustainability*, 5 (2), 021001 <https://doi.org/10.1115/1.4065053>
- Mondal, S., Faruk, F. B., Rajbongshi, D., Efaz, M. M., and Islam, M. M. (2023). GEECO: Green Data Centers for Energy Optimization and Carbon Footprint Reduction. *Sustainability*, 15 (21). <https://doi.org/10.3390/su152115249>
- Murino, T., Monaco, R., Nielsen, Per S., Liu, X., Esposito, G., Scognamiglio, C. (2023). Sustainable Energy Data Centres: A Holistic Conceptual Framework for Design and Operations. *Energies*, 16 (15). <https://doi.org/10.3390/en16155764>
- Osibo, B., and Adamo, S. (2023). Data Centers and Green Energy: Paving the Way for a Sustainable Digital Future. *International Journal of Latest Technology in Engineering, Management & Applied Science*, 12 (11), 15-30. <https://doi.org/10.51583/IJLTEMAS.2023.121103>
- Qasim, N., and Pyliavskiy, V. (2020). Color temperature line: forward and inverse transformation. *Semiconductor physics, quantum electronics and optoelectronics*, 23, 75-80. <https://doi.org/10.15407/spqeo23.01.075>
- Qasim, N., Shevchenko, Y.P., and Pyliavskiy, V. (2019). Analysis of methods to improve energy efficiency of digital broadcasting. *Telecommunications and Radio Engineering*, 78 (16), 1457-1469. <https://doi.org/10.1615/TelecomRadEng.v78.i16.40>
- Qasim, N. H., Salman, A. J., Salman, H. M., AbdelRahman, A. A., and Kondakova, A. (2024). Evaluating NB-IoT within LTE Networks for Enhanced IoT Connectivity. *35th Conference of Open Innovations Association (FRUCT)*, 552-559. <https://doi.org/10.23919/FRUCT61870.2024.10516400>
- Ran, Y., Hu, H., Wen, Y., and Zhou, X. (2023). Optimizing Energy Efficiency for Data Center via Parameterized Deep Reinforcement Learning. *IEEE Transactions on Services Computing*, 16 (2), 1310-1323. <https://doi.org/10.1109/TSC.2022.3184835>
- Sviridov, A. N., and Demkin, V. I. (2022). ANALYSIS OF INCREASING THE DATA CENTERS ENERGY EFFICIENCY METHODS. *Modern High Technologies*, 2, 110-115. <https://doi.org/10.17513/snt.39044>
- Wan, J., Duan, Y., Gui, X., Liu, C., Li, L., and Ma, Z. (2023). SafeCool: Safe and Energy-Efficient Cooling Management in Data Centers With Model-Based Reinforcement Learning. *IEEE Transactions on Emerging Topics in Computational Intelligence*, 7 (6), 1621-1635. <https://doi.org/10.1109/TETCI.2023.3234545>
- Xu, S., Zhang, H., and Wang, Z. (2023). Thermal Management and Energy

Consumption in Air, Liquid, and Free Cooling Systems for Data Centers: A Review. *Energies*, 16 (3). <https://doi.org/10.3390/en16031279>

Yousif, O., Dawood, M., Jassem, F. T., and Qasim, N. H. (2024). Curbing crypto deception: evaluating risks, mitigating practices and regulatory measures for preventing fraudulent transactions in the middle east. *Encuentros: Revista de Ciencias Humanas, Teoría Social y Pensamiento Crítico*, (22), 311-334. <https://doi.org/10.5281/zenodo.13732337>

Zhang, Y., and Liu, J. (2022). Prediction of Overall Energy Consumption of Data Centers in Different Locations. *Sensors*, 22 (10). <https://doi.org/10.3390/s22103704>